

# Certificate

Registration No.: PV 50188584

Page 1

Report No.: 15036761.001

**License Holder:**

**Jiangyin Hareon Power Co., Ltd.**

No. 178 Huanzhen North Road,  
Huangtang Industrial Zone,  
Xuxiake Town, Jiangyin, Jiangsu 214408  
P.R. China

**Product:**

PV Modules

Type:

With 60 cells of 6" mono c-Si:  
HR-xxx-18/Cb (xxx=200-240, in increment of 5)

With 72 cells of 6" mono c-Si:  
HR-xxx-24/Ca (xxx=235-290, in increment of 5)

**Manufacturing plant:**

**Jiangyin Hareon Power Co., Ltd.**

No. 178 Huanzhen North Road,  
Huangtang Industrial Zone,  
Xuxiake Town, Jiangyin, Jiangsu 214408  
P.R. China

With 60 cells of 6" poly c-Si:  
HR-xxxP-18/Bb, (xxx=200-245, in increment of 5)

With 72 cells of 6" poly c-Si:  
HR-xxxP-24/Ba (xxx=245-290, in increment of 5)

**Basis:**

- IEC 61730-1:2004  
IEC 61730-2:2004  
EN 61730-1:2007  
EN 61730-2:2007  
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**
- **Periodic inspection**

**Remarks:**

- IEC EN 61730 consists of part 1 ( Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II ). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 15036571.001.

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

**The certificate is valid until 10 August 2015.**



Certification body

Dipl.-Ing. Bernd Scheirer

Shanghai, 18 October 2010