

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced specifications at the time the tests were carried out.

Applicant Name & Address	: ReneSola Jiangsu Ltd No.27, Qingyuan Road (East), Yixing Economic Development Zone, Yixing city, Jiangsu Province, 214200 P.R.China
Manufacturing site Name & Address	: Same as applicant
Product(s) Tested	: Crystalline Silicon Terrestrial Photovoltaic Module
Ratings and principal characteristics	: DC 1000V, Class of application A, Class II, Fire resistance class C, Maximum over-current protection rating 15A
Model(s)	: JC250M-24/Bb, JC300M-24/Ab, JC255M-24/Bbv, JC305M-24/Bbv, JC255S-24/Bb, JC305S-24/Bb With same manufacturer and same manufacture technology and process shall also refer to this report
Brand name	: Renesola
Relevant Standard(s)/Specification(s)	: IEC 61701, First edition, 1995.3 Salt mist corrosion testing of photovoltaic (PV) modules
Verification Issuing Office Name & Address	: Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Verification Number	: SH11070849-V2
Report Number(s)	: SH11070849-002

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

NOTE 2: This verification supersedes all previous verifications with the noted Verification/Report number(s) dated before this verification issuance.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Leo Shi
Manager
21 Aug. 2012